

Indoor Structures

- Two (2) or more walls, flaps, sides and a roof
- Dining area must be designed so that patrons are at least six (6) feet apart and **25%** (12/14/2020) of normal capacity
 - Igloos or other structures that are designed and used for single parties (6 or less) are not required to reduce by 25%
- Dining area must have at least five (5) air changes per hour and not more than fifty percent (50%) recirculation air shall be permitted



Outdoor Structure

- No more than one (1) wall, flap, side
- Dining area must be designed so that patrons are at least six (6) feet apart



Capacity Determination



- Capacity for permanent indoor structures determined from Certificate of Occupancy
- Capacity for temporary structures determined from specification sheet

